

Quantification of primary frequency control provision from battery energy storage systems connected to active distribution networks

Giacomo - Piero Schiapparelli, Stefano Massucco
DITEN, University of Genova, Genova, Italy
schiapparelli.g@gmail.com, stefano.massucco@unige.it

Emil Namor, Fabrizio Sossan, Rachid Cherkaoui,
Mario Paolone
DESL, EPFL, Lausanne, Switzerland
{emil.namor, fabrizio.sossan, rachid.cherkaoui,
mario.paolone}@epfl.ch

Abstract—In this paper, we consider the provision of primary frequency control by using battery energy storage systems (BESSs). In particular, we use a standard droop-based frequency control for a BESS where the control action (i.e. the BESS power output) consists in the contribution of two additive terms: the regulating power, proportional to the frequency deviations, and an offset term computed to manage the BESS State-of-Energy (SOE). In the context of such a control scheme, we propose a method to forecast the BESS energy for regulation needs and we show that the inclusion of such a forecast can increase the regulating power provision. Finally, we demonstrate the performance of the proposed approach by means of a real-scale experimental setup composed by a grid-connected 720 kVA/560 kWh BESS installed at the EPFL campus in Lausanne, Switzerland.

Index Terms—Battery energy storage systems, primary frequency regulation, control, forecast.

I. INTRODUCTION

There is a general technical consensus that the progressive displacement of conventional generation in favour of production from renewable sources requires distributed generation (DG) and storage to provide grid ancillary services. In this context, grid-connected battery energy storage systems (BESSs) are gaining increasing focus thanks to their fast ramping compared to conventional generation units [1]–[3]. Several authors have proposed different methods to provide primary frequency regulation (PFR) with BESSs, e.g. by using adaptive droop control [4], offset frequency control signals [5] and model predictive control (MPC) exploiting short-term predictions of the grid frequency [6]. In this paper, we consider the problem of the provision of PFR with BESSs using a droop-based control strategy. The control is composed by three consecutive phases: *i*) the *a-priori* computation of the droop coefficient with an optimisation problem; *ii*) the periodical (with a period of length T , ranging from 1 to 24 hours), computation of an offset power to maintain continuous operation, based on the BESS state of energy (SOE) and forecast of the energy needed for regulation via autoregressive (AR) models; *iii*) the real-time control, which implements a power setpoint consisting in the sum of the regulating and offset power.

With regard to this general control structure we: *i*) introduce two forecasting methods to predict the energy needed for regulation over subsequent periods by using AR models of different orders; *ii*) compute the maximum possible regulating capacity according to technical constraints and desired reliability requirements; *iii*) examine how the duration of the period for the computation of both the droop coefficient and the power offset affect the performance of such control scheme and *iv*) validate the method by simulations and experiments with a grid-connected BESS.

An extensive comparison between the two forecasting methods is carried out to assess the benefits of incorporating the forecast of the regulating energy need in the proposed control. The performance of the proposed control framework is validated by simulations in Matlab/Simulink and experimentally tested using a grid-connected 720 kVA/560 kWh BESS installed at the EPFL campus in Lausanne, Switzerland [7].

The contributions of this paper are twofold. First, we introduce a method to forecast the BESS energy need due to PFR and we demonstrate that it allows to increase the provision of regulating power. Second, we perform an extensive experimental campaign to: *i*) evaluate the reliability and success rate of the control framework; *ii*) evaluate the ability of the BESS to follow the regulation signal, with performance metrics as in [8]; *iii*) infer the long-term performance of the proposed method using the above mentioned simulation environment.

The rest of the paper is structured as follows. In Section II, we describe the methods to forecast the energy need of a BESS performing PFR. In Section III, we describe the implemented control algorithms. In Section IV, the main simulation and experimental results are presented. Section V summarizes the main contributions and perspectives of this paper.

II. FORECAST OF ENERGY REQUIRED FOR REGULATION

Since BESSs can store a limited amount of energy, in order to provide a given amount of regulating power for a predetermined duration, a BESS needs to continuously adopt its reservoir level. Therefore, in order to maximise the capacity of providing regulating power, it is important to quantify the energy that the BESS needs to make available to accomplish

the PFR service provision over a future period of duration period T . Since regulating power P_{pfr} is proportional to frequency deviations Δf from the nominal frequency, the regulating energy E_{pfr} is proportional to the integral of such deviations over the considered interval:

$$E_{pfr} = \int_T P_{pfr} dt = \int_T \alpha \Delta f dt = \alpha \int_T \Delta f dt = \alpha W_f, \quad (1)$$

where W_f is the integral over a time window T of the deviations of frequency from its nominal value, and α is the droop coefficient in kW Hz^{-1} . It is worth noting that (1) assumes that the regulating power is also deployed in response to frequency deviations within ± 10 mHz. Typically, European grid codes do not require activation within this band [9]. However, it can be demonstrated that the disregard of such practice has a negligible effect on the resulting W_f values and on the subsequent control.

The quantity W_f , over a long enough time horizon is equal to zero (considering a power grid with a sufficient amount of secondary frequency control reserve). However, this is not generally true for shorter intervals, and we show that it is possible to forecast the value of W_f and use it to achieve efficient PFR strategies. The analysis detailed in these paragraphs has been carried out on two separate datasets, respectively composed by two years (2014-2015) of frequency measurements collected by National Grid Electricity Transmission (NGET)¹ and by one year (2016) of on-site frequency measurements at EPFL [10]. From the frequency timeseries, we have computed several W_f timeseries, with integration intervals T of increasing length from 1 to 24 hours. The objective is to verify the possibility to use autoregressive models (AR) in order to forecast W_f .

The usage of AR models requires the analysis of the probability density function of the variable W_f and its autocorrelation [11]. Figure 1 shows in red the quantile-quantile plots obtained for two W_f timeseries (respectively from the NGET and EPFL databases and with different T) and in blue the same plot for the quantiles of a normal distribution. Such plots demonstrate that the data of such timeseries are close to normally distributed and suggest the use of AR models.

Figure 2-a shows the autocorrelation of the timeseries composed by subsequent W_f values computed for the NGET database and with $T=1\text{h}$ as an example. Modelling such timeseries as a persistent process (i.e. assuming that there are not relevant dynamics that can be captured), at every timestep we predict the value $\widehat{W}_f(k) = \mu_f = 0$. For such model (hereafter AR(0)), the model residual corresponds the value of W_f itself, being $r_k = W_f(k) - \widehat{W}_f(k) = W_f$. We see that the residuals for such model present an autocorrelation that is, for the lower lags, higher than for white noise (indicated by the blue lines in the plot). This suggests that W_f contains dynamics that can be modelled with an higher order model. Figure 2-b shows the autocorrelation of the model residuals obtained, for the same dataset, with an autoregressive model of order 8 (i.e.

¹Dataset downloaded from <http://www2.nationalgrid.com/Enhanced-Frequency-Response.aspx> on April 24th, 2017.




Figure 1. Q-Q plot of the residuals of W_f (red) versus the normal standard (blue) built using a) $T = 1h$, data from the NGET database and b) $T = 6h$, data from EPFL database.




Figure 2. Autocorrelation function of the residuals of a) AR(0) and b) AR(8), both computed with $T=1\text{h}$ and data from the NGET database.

the lowest order that successfully captures all the relevant dynamics for all the period lengths T), hereafter referred as AR(8). It can be seen that the residual autocorrelation does not show, in this case, any value outside the band identifying white noise. Similar results are obtained for all values of T and for both datasets considered (not reported here for sake of space). Table I compares the standard deviation of the residuals of models AR(0) and AR(8) obtained for integration periods T of increasing duration. It can be observed that this value is lower for the AR(8) model for all T .

TABLE I
RESIDUAL STANDARD DEVIATION σ FOR AR(0) AND AR(8), DATA FROM NGET DATABASE.

T [h]	1	2	3	4	6	12	24
AR(0)	96	154	201	243	312	428	575
AR(8)	92	150	197	239	307	408	516

Using such a prediction model provides two relevant results for the PFR control strategy. First, a model with lower variance allows to use a higher droop coefficient and therefore provide higher regulating power (as detailed in Section III-A). Second, the predicted value \widehat{W}_f , recomputed periodically, can be used to improve the state of energy management associated to such droop coefficient (as detailed in Section III-B).

III. CONTROL STRATEGY

The BESS control consists in a standard droop-based frequency regulation strategy where the BESS's active power output is given by the sum of the regulating power P_f and the offset term P_{SOE} , computed periodically to keep the SOE within its technical bounds. For each period, the control is designed to restore the reference condition of State-of-Energy, SOE_0 . It acts in three stages:

- 1) *a-priori* computation of the droop coefficient α given by the solution of an optimization problem. The latter takes into account the statistical properties of W_f to determine the maximum value of α (hereafter α_{max}) that can be used for periods of the given duration T . The resulting α_{max} is then fixed for all considered periods T or, in the context of ancillary service markets, fixed within the time horizon for the bidding of the frequency regulation service (e.g. one week).
- 2) the period-ahead operation where, on the basis of the forecast of the energy required for one period of operation T and the knowledge of the SOE of the BESS, the offset term P_{SOE} for such period is computed. This task is defined hereafter as *State-of-Energy Management* (SOE-M) and is repeated for each i -th period T_i ;
- 3) the real-time control, where the regulating action is actuated with 1 second resolution.

Figure 3 shows the control diagram.

A. Droop coefficient computation

The BESS SOE is defined as the integral over the time of the power output of the battery²:

$$SOE(T_i + t) = \frac{1}{E_n} \cdot \int_{T_i}^{T_i+t} P(\tau) d\tau + SOE(T_i) \quad (2)$$

$$= \frac{\alpha}{E_n} \cdot \int_{T_i}^{T_i+t} \Delta f(\tau) d\tau + SOE(T_i), \quad (3)$$

where E_n is the BESS nominal energy capacity. The value of the droop coefficient α is determined by solving the optimisation problem detailed below, aiming at maximizing the droop coefficient while respecting the constraints on the energy that can be stored in the battery. The optimization constraints are built to ensure a continuous operation of the battery. Starting from an initial condition of $SOE(T_i) = SOE_0$, the maximum deviation during one period T must be equal to SOE_0 , thus, $0 \leq SOE(T_{i+1}) \leq 2SOE_0$. Therefore, since $SOE(T_{i+1}) \in \{0, 1\}$, the reference condition SOE_0 has to be chosen in the range $[0, 0.5]$. From equation (3), $SOE(T_{i+1})$ can be expressed as function of W_f :

$$SOE(T_{i+1}) = \frac{\alpha \cdot W_f}{E_n} + SOE(T_i). \quad (4)$$

Therefore, considering a confidence level ρ and the value distribution of the residuals of the energy need forecasting

²At this stage we are neglecting the battery losses. In Section IV-B we will show that these have a negligible impact on the computation of α and that the ΔSOE due to the battery losses can be absorbed by the offset power computed for the subsequent period T_{i+1} .




Figure 3. Block diagram of the proposed method to operate the PFR.

as defined in section II, the optimization problem can be expressed as:

$$\alpha_{max} = \arg \max_{\alpha} \{\alpha\} \quad (5)$$

subject to:

$$SOE(T_{i+1}) = \frac{\alpha \cdot W_f}{E_n} + SOE(T_i) \quad (6)$$

$$Pr(|SOE(T_{i+1}) - SOE(T_i)| \leq SOE_0) \geq \rho \quad (7)$$

where $Pr(\cdot)$ denote the probability that the argument occurs. This problem has an analytical solution. By applying (4), (7) can be written as:

$$Pr\left(|W_f| \leq \frac{SOE_0 E_n}{\alpha}\right) \geq \rho. \quad (8)$$

Since W_f is a normally distributed stochastic process with variance σ_f (as shown in Section II), Eq. 8 is satisfied by:

$$\alpha \leq \frac{SOE_0 \cdot E_n}{k \cdot \sigma_f} \quad (9)$$

where the value of k is related to that of the selected ρ , e.g. $k = 1.96$ for $\rho = 0.95$, $k = 2.58$ for $\rho = 0.99$, etc..

Since the objective in 5 is to maximise the regulating power provided with the BESS, the maximum droop coefficient and solution of the problem 5-7 is:

$$\alpha_{max} = \frac{E_n \cdot SOE_0}{k \cdot \sigma_f}. \quad (10)$$

The value of the standard deviation of the residuals σ_f depends on the autoregressive model used and length of the period T . An autoregressive model of higher order, such as AR(8) has a lower variance of the residuals obtained with an AR(0) model. Therefore, its use is convenient as it leads to a higher value for α and a higher regulating capacity.

B. State-of-Energy Management

The SOE-M uses a power offset profile to restore the initial condition, SOE_0 , at the beginning of each consecutive operation period in order to ensure a reliable and continuous regulation. At the beginning of the period, the SOE-M measures the SOE of the battery, forecasts the evolution of the SOE in the next period and, on the basis of this result, computes the offset power profile. The offset power is computed to avoid hitting the SOE limits in the upcoming period of operation. To achieve this goal, the prediction of the SOE variation due to regulation at the end of the upcoming period, which is provided by the forecasting methods detailed in section II,

is exploited. When using the AR(0) model, the predicted SOE at the end of the upcoming period of operation, $\widehat{SOE}(T_{i+1})$, is equal to the current one $\widehat{SOE}(T_i)$. An autoregressive model of higher order, such as AR(8), allows for a more precise prediction and $\widehat{SOE}(T_{i+1})$ will differ, in general, from $\widehat{SOE}(T_i)$. The energy to be exchanged by the BESS in the following period will be therefore:

$$\widehat{E}_{SOE} = [SOE_0 - \widehat{SOE}(T_{i+1})] E_n, \quad (11)$$

where:

$$\widehat{SOE}(T_{i+1}) = \widehat{SOE}(T_i) \quad \text{for AR(0),} \quad (12)$$

$$\widehat{SOE}(T_{i+1}) = \widehat{SOE}(T_i) + \Delta\widehat{SOE}_i \quad \text{for AR(8).} \quad (13)$$

The offset power to satisfy such energy need is set to be constant over the period $T_{i+1} - T_i$, and equal to:

$$P_{SOE}^i = \frac{[SOE_0 - \widehat{SOE}(T_{i+1})] \cdot E_n}{T_{i+1} - T_i}. \quad (14)$$




Figure 4. Expected trajectories of the energy stored in the BESS over a period T a) without and b) with the action of the SOE-M.

The impact of the offset profile is shown graphically in Figure 4. At the beginning of the period the state of energy is in principle different from SOE_0 . Moreover, the expected SOE at the end of the period will vary of a quantity $\Delta\widehat{SOE}_i$, predicted via the models proposed in Section II. The space of the expected trajectories for the upcoming period therefore is tilted by a quantity which depends on the value of $SOE(T_i)$ and $\Delta\widehat{SOE}_i$. At the end of the period, the state of energy is expected to be in the range $[\widehat{SOE}(T_{i+1}) \pm k \cdot \sigma_{E_f}]$. Such interval may exceed the range of capable SOE, and so the reliability of the PFR provision can not be ensured (see Figure 4-a).

When the offset profile is implemented, the space of the expected trajectories is modified. The offset power is constant over all the period, so the energy injected or extracted from the battery during such period follows a linear increasing or decreasing shape,

$$SOE_{SOE}^i(t) = \frac{1}{E_n} \int_0^t P_{SOE}^i(\tau) d\tau = \frac{P_{SOE}^i}{E_n} \cdot t. \quad (15)$$

therefore, the expression of the evolution of the state of energy during the time can be written as:

$$\begin{aligned} SOE(T_i + t) &= \frac{1}{E_n} \int_{T_i}^{T_i+t} [\pm P_{SOE}^i(\tau) + P_f(\tau)] d\tau + SOE(T_i) \\ &= + \frac{P_{SOE}^i}{E_n} \cdot t + \alpha \frac{W_f(t)}{E_n} + SOE(T_i). \end{aligned} \quad (16)$$

The addition of the power offset profile impacts the evolution of the state of energy by aligning the confidence interval on $SOE(T_{i+1})$ with the BESS capability. From the graphical point of view, these relationships can be interpreted as in figure 4-b. Applying a constant power offset, the impact on the evolution of the SOE consist in a ramp added to the state of energy trajectory. The space of the possible trajectories is therefore shifted and the confidence level, at the end of the following period, results to be centered within the capability of the BESS.

C. Real-time control

In real-time, the frequency deviation Δf is measured with 1 second resolution and every second the BESS power set-point is refreshed as:

$$P_{BESS} = \Delta f \cdot \alpha + P_{SOE}. \quad (17)$$

Where the value of α_{max} is determined a priori as in subsection III-A and the value of P_{SOE} is computed as described in Section III-B and updated once every period T .

IV. RESULTS

In this Section, the main results obtained by applying the proposed methods are shown. Notably, Subsection IV-A shows the values of droop coefficients determined for the two datasets, the two forecasting models and for various values of T . Subsection IV-B shows the simulation results obtained for such values and compares the performances of the control based on AR(0) and on AR(8). Finally, Subsection IV-C shows results obtained applying the proposed methods to the control of a 720 kVA/560 kWh grid-connected BESS. These are with the objective of validating experimentally the proposed methods, evaluating the BESS performances in performing PFR and validating the simulation environment used in Subsection IV-B.

A. Droop coefficient computation

The algorithm for the computation of the droop coefficient α_{max} has been used for each of the considered periods. Tables II and III show such results. Notably, Table II refers to the droop coefficient values computed from the frequency dataset provided by NGET. Table III, refers to the data collected in one year at the EPFL campus and that have been used in the experiments described in Section IV-C.

The method presented in Section III-A determines the value of α_{max} on the basis of the energy capability of the BESS. In the case of the EPFL 720 kVA/560 kWh BESS, since both energy and power ratings are given, also the latter should be used to determine the α_{max} . The theoretical value of α_{max} corresponds to the minimum value between α_{max}^e (i.e. the maximum droop coefficient based on the BESS energy capability, found as in Section III-A) and α_{max}^p (i.e. the maximum droop coefficient compatible with the BESS power ratings). The latter term can be computed as follows:

$$P_{SOE}^{max} = \frac{SOE_0 \cdot E_n}{T_{i+1} - T_i}, \quad (18)$$

$$P_f^{max} = P_0 - P_{SOE}^{max}, \quad (19)$$

$$\alpha_{max}^p = \frac{P_f^{max}}{\Delta f_{max}}, \quad (20)$$

where P_{SOE}^{max} is the maximum possible value of the power offset, P_0 is the rated power of the BESS, and P_f^{max} is the maximum regulating power. All the values in Table III have been computed considering a grid-connected 720 kVA/560 kWh BESS and the activation of full reserve power for frequency deviation beyond ± 200 mHz, as dictated by ENTSO-E grid codes [12].

TABLE II
DROOP COEFFICIENT VALUES [kW/Hz], NGET DATABASE.

T [h]	ρ	1	2	3	4	6	12	24
AR(0) model								
α_{max}^e	95%	5325	3321	2555	2115	1646	1201	893
α_{max}^e	99%	4046	2523	1941	1607	1251	913	679
AR(8) model								
α_{max}^e	95%	5567	3415	2607	2144	1674	1259	995
α_{max}^e	99%	4230	2595	1981	1629	1272	957	756

Table III shows that for the EPFL 720 kVA/560 kWh BESS and for the $T \leq 6$ h, the theoretical value of α_{max} is determined by the BESS power ratings rather than its energy capability. In Section IV-C, details are given about the values of T and α_{max} used to experimentally validate the methods proposed in this paper with the specific ratings of the EPFL BESS.

B. Simulations

The performance of the proposed control framework is validated by simulations in Matlab/Simulink. The simulator uses one year of frequency measurements for the NGET database as

TABLE III
DROOP COEFFICIENT VALUES [kW/Hz], EPFL DATABASE ($\rho = 95\%$).

T [h]	1	2	3	4	6	12	24
AR(0) model							
α_{max}^e	14807	8524	6278	4959	3623	2270	1270
α_{max}^p	2200	2900	3133	3250	3366	3483	3541
AR(8) model							
α_{max}^e	17216	9751	7337	5895	4302	2633	1386
α_{max}^p	2200	2900	3133	3250	3366	3483	3541

input and the BESS state of energy as output. It presents two different models of BESS. In the *ideal* model the losses are not taken into account, whereas in the *real* one the losses are modeled as in [7]. Specifically the battery is considered as the series of a voltage sources and a resistance and the values of both depend on the battery state of charge (SOC). The SOE-M performance in the simulation environment has been evaluated for three periods T , two different confidences levels (95% and 99%), and for the two different autoregressive models ($AR(0)$ and $AR(8)$). The results of these simulations are evaluated by quantifying the failure rate λ_T . The SOE-M fails in its control when the BESS reaches its capability limits and cannot provide power for frequency regulation. The control failure rate λ_T corresponds to the duration of the period in which the BESS is not able to perform its tasks, expressed in percentage of the simulation duration. From the definition of the droop coefficient given in Section III-A, over one period of operation the expected failure rate is related to the confidence ρ on the control action as follows:

$$\tilde{\lambda}_T = 1 - \rho. \quad (21)$$

TABLE IV
SIMULATION RESULTS, NGET DATABASE

<i>BESS model</i>	ρ	T	<i>AR(0)</i>		<i>AR(8)</i>	
			α_{max}	$\tilde{\lambda}_T$	α_{max}	$\tilde{\lambda}_T$
	[%]	[h]	[kW/Hz]	[%]	[kW/Hz]	[%]
Ideal	95%	24	893	3.631	995	4.723
Real	95%	24	893	4.423	995	6.410
Real	99%	24	679	0.358	755	0.358
Ideal	95%	12	1201	4.087	1259	4.609
Real	95%	12	1201	4.779	1259	5.223
Real	99%	12	912	0.616	957	0.799
Ideal	95%	1	5325	2.992	5567	2.472
Real	95%	1	5325	5.086	5567	2.452
Real	99%	1	4045	0.408	4229	0.350

Table IV presents the results of the simulations. The failure rate λ_T is on average equal to 3.8% for the simulation based

on a $\rho=95\%$ and a BESS with unitary efficiency and to 4.7% for the simulation based on a $\rho=95\%$ and a BESS with non-unitary efficiency. In both cases the average failure rate for the simulation is close to the expected value of 5%. Moreover, it can be observed that the introduction of a more accurate BESS efficiency model does not provide results considerably different from those obtained for an ideal BESS.

C. Experiments

The algorithm has been tested experimentally using a dedicated setup consisting in a grid-connected 720 kVA/560 kWh BESS installed at the EPFL campus in Lausanne [7]. Frequency measurements are from an on-site PMU-based metering system [10]. Three sets of experiments have been carried out.

The purpose of the first group of experiments is the evaluation of the ability of the algorithm to ensure the rated reliability. Such series of experiments has been carried out for $T=3h$ and $T=6h$ and with the α_{max} defined as in section III-A, based on the BESS energy capability. The choice of $T=3h$ and $T=6h$, although in contrast with the results presented in Table III, is justified by two observations. On one hand, experiments based on $T=12h$ or $T=24h$ would need a considerably long run-time to achieve statistically relevant results. On the other side, for smaller T , an α_{max} computed as in Section III-A would generate an ineffective regulation, since even for deviations of relatively small magnitude, the BESS power would be limited by its power rating and the regulation signal would not be tracked accurately. For $T=3h$ and $T=6h$, the power rating of the battery would limit the BESS power from tracking the regulating signal only in the occurrence of large and infrequent frequency deviations ($\Delta f > 100mHz$). These values of T are therefore suited to the purpose of validating the proposed method, although the consideration of the power ratings should be taken into account in the sizing phase of a BESS designed to perform PFR.

Figure 5 shows the result of EXP5. The control fails every time the SOC is near to the limits and the battery is not able to implement the set points received from the control logic. The results of this first set of experiments are summarised in




Figure 5. Evaluation of the reliability. Results from EXP5. Top: power output, middle: absolute error between setpoint and measurement, bottom: SOE.

Table V and consist of almost 500h of PFR divided in four

experiments with duration H of 23 periods and 30 periods, respectively. The observed failure rates $\hat{\lambda}_T$ for each experiment are in the neighbourhood of the expected value $\hat{\lambda}_T = 5\%$ with the experiment based on $AR(0)$ and $T=6h$ being the one in which $\hat{\lambda}_T$ is the more distant from this value, having a $\hat{\lambda}_T = 2.86\%$.

TABLE V
EXPERIMENTAL RESULTS: RELIABILITY AND FAILURE RATE.

Name	Model	T [h]	H [periods]	α_{max} [kW/Hz]	$\hat{\lambda}_T$ [%]
EXP3	AR8	3h	23	7337	5.9871
EXP4	AR0	3h	23	6278	5.7596
EXP5	AR0	6h	30	4302	2.8565
EXP6	AR8	6h	30	3623	5.5144

The second group of experiments aims to assess the ability of the BESS to follow the regulating signal. With regard to this purpose, the performance metrics chosen are the ones adopted by PJM Interconnect [8]. Such parameters evaluate the regulating action for each hour of service giving a general score which is the mean of three parameters delay correlation and precision. Figure 6 shows the performance scores for the 560kWh BESS object of this study, obtained on an experiment with period $T=1h$ and a droop coefficient $\alpha=2200 kW Hz^{-1}$ and with overall duration of about 40 hours. Similar values has been registered in all the experiments presented and are aligned with the expectations for the battery which are usually around 96-99% [13].




Figure 6. Performance assessment in providing frequency regulation services. Experimental results obtained for $T=1h$ and $\alpha=2200kW Hz^{-1}$.

The objective of the third group of experiments is gathering experimental data to playback in the simulator in order to validate its output and support the proposed simulation results. To quantify this, data from the experiments presented in Section IV-C has been fed as input for the simulator and the power and SOE profiles generated by the simulations have been compared to the experimental data. The accuracy of the simulation environment has been quantified via the RMS value of the difference between the measured and simulated SOE, ΔSOE^{RMS} . Table VI shows the rms value of the

TABLE VI
EXPERIMENTAL RESULTS: VALIDATION OF SIMULATION ENVIRONMENT.

Name	Model	T [h]	H [periods]	α_{max} [kW/Hz]	ΔSOE_{RMS} [-]
EXP1	AR0	1	39	2200	0.007
EXP2.1	AR8	1	24	2200	0.009
EXP2.2	AR8	1	42	2200	0.006
EXP2.3	AR8	1	30	2200	0.005
EXP3	AR8	3	23	7337	0.028
EXP4	AR8	3	23	6278	0.107
EXP5	AR0	6	30	4302	0.076

difference between measured and simulated SOE for various experiments. This value is on average of 0.034, indicating satisfactory simulation performances. Figure 7 shows the SOE profiles for one of such experiments. The simulated SOE matches closely the measured one, except for the moments when the control fails due to a SOE approaching its lower bound. This difference at extreme SOE values is due the fact that the BESS internal controller imposes SOE limits that are dynamic and not always corresponding to the static bounds used in the simulation tool. Nonetheless, good simulation performances are achieved for a wide SOE range.




Figure 7. Performance assessment of the simulation tool, scenario from EXP3.

V. CONCLUSIONS

We present a droop-based control framework to perform primary frequency regulation by using a BESS. The computation of the droop coefficient and the state of energy management rely on the forecast of the energy needed for regulation over a multi-hour horizon, performed by means of autoregressive models. We show that, by exploiting the information provided by such forecasts, the BESS control can exploit a higher droop coefficient value (and thus provide more regulating power), while ensuring the same level of reliability of a base case, AR(0), in which such information is not exploited. This constitutes an improvement over typical offset-based controls for BESSs providing frequency regulation (e.g. [5], [14]), although it requires large datasets of historical data (not always easily accessible) to train the autoregressive models.

The proposed method is both validated via simulations and implemented in the control of a grid-connected 720 kVA/560 kWh Lithium titanate BESS. The experiments carried out in the present work demonstrate the effectiveness as well as the practical deployability of the proposed control framework. Moreover, we exploit experimental data to assess the performances of the BESS in providing primary frequency regulation, which prove to be extremely high.

Future works concern the improvement of the forecasting tools performance, the introduction of a period-based computation of the droop coefficient (e.g. definition of α on a weekly basis) and the coupling of the proposed optimal control scheme with an upper-level optimization problem to determine the optimal battery capacity.

REFERENCES

- [1] A. Malhotra, B. Battke, M. Beuse, A. Stephan, and T. Schmidt, "Use cases for stationary battery technologies: A review of the literature and existing projects," *Renewable and Sustainable Energy Reviews*, vol. 56, pp. 705–721, 2016.
- [2] H. Bevrani, *Robust power system frequency control; 2nd ed.*, ser. Power Electronics and Power Systems. Dordrecht: Springer, 2014. [Online]. Available: <http://cds.cern.ch/record/1967886>
- [3] *Energy storage and storage services, ENTSO-E position*. ENTSO-E, October 2016.
- [4] X. Lu, K. Sun, J. M. Guerrero, J. C. Vasquez, and L. Huang, "State-of-charge balance using adaptive droop control for distributed energy storage systems in dc microgrid applications," *IEEE Transactions on Industrial electronics*, vol. 61, no. 6, pp. 2804–2815, 2014.
- [5] O. Mège, J. L. Mathieu, and G. Andersson, "Maximizing the potential of energy storage to provide fast frequency control," in *Innovative Smart Grid Technologies Europe (ISGT EUROPE), 2013 4th IEEE/PES*. IEEE, 2013, pp. 1–5.
- [6] M. Khalid and A. V. Savkin, "Model predictive control based efficient operation of battery energy storage system for primary frequency control," in *Control Automation Robotics & Vision (ICARCV), 2010 11th International Conference on*. IEEE, 2010, pp. 2248–2252.
- [7] F. Sossan, E. Namor, R. Cherkaoui, and M. Paolone, "Achieving the dispatchability of distribution feeders through prosumers data driven forecasting and model predictive control of electrochemical storage," *IEEE Transactions on Sustainable Energy*, vol. 7, no. 4, pp. 1762–1777, Oct 2016.
- [8] C. Pilong, *PJM Manual 12: Balancing Operations*, 36th ed., PJM, January 2017.
- [9] B. Xu, A. Oudalov, J. Poland, A. Ulbig, and G. Andersson, "Bess control strategies for participating in grid frequency regulation," *IFAC Proceedings Volumes*, vol. 47, no. 3, pp. 4024–4029, 2014.
- [10] M. Pignati, M. Popovic, S. Barreto, R. Cherkaoui, G. D. Flores, J.-Y. Le Boudec, M. Mohiuddin, M. Paolone, P. Romano, S. Sarri *et al.*, "Real-time state estimation of the epfl-campus medium-voltage grid by using pmus," in *Innovative Smart Grid Technologies Conference (ISGT), 2015 IEEE Power & Energy Society*. IEEE, 2015, pp. 1–5.
- [11] H. Madsen, *Time Series Analysis*, ser. Chapman & Hall/CRC Texts in Statistical Science. Taylor & Francis, 2007.
- [12] B. Xu, A. Oudalov, J. Poland, A. Ulbig, and G. Andersson, "Bess control strategies for participating in grid frequency regulation," *IFAC Proceedings Volumes*, vol. 47, no. 3, pp. 4024–4029, 2014.
- [13] E. P. M. Co, "Final technical performance report: Grid-scale energy storage demonstration of ancillary services using the ultrabattery technology," East Penn Manufacturing Co, Tech. Rep. DE-OE0000302, August 2015.
- [14] A. Oudalov, D. Chartouni, and C. Ohler, "Optimizing a battery energy storage system for primary frequency control," *IEEE Transactions on Power Systems*, vol. 22, no. 3, pp. 1259–1266, 2007.